

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

November 15, 2017

Carlos Luna  
Atwood Heights School District 125  
12150 South Hamlin Ave.  
Alsip, IL 60803

Workorder: 1711379

TEL: (773) 827-8221

FAX:

RE: Hamlin Upper Grade Center 12150 South Hamlin Avenue Alsip IL 60803  
Drinking Water Lead Analysis

Dear Carlos Luna:

Suburban Laboratories, Inc. received 14 sample(s) on 11/6/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez  
Project Manager  
708-544-3260 ext 214  
pat@suburbanlabs.com



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Atwood Heights School District 125

**Project Name:** Hamlin Upper Grade Center 12150 South Hamlin Avenue

**Report Date:** November 15, 2017

**Workorder:** 1711379

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711379-001A	Outside Rm 5 Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-002A	Outside Rm 5 Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-003A	Outside Rm 4 Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-004A	Outside Rm 4 Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-005A	Kitchen	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-006A	Kitchen	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-007A	Hallway 4 New Sect	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-008A	Hallway 4 New Sect	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-009A	Hallway 5 New Sect	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-010A	Hallway 5 New Sect	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-011A	Locker Room 6	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-012A	Locker Room 6	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-013A	Locker Room 7	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711379-014A	Locker Room 7	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

November 15, 2017

Carlos Luna  
Atwood Heights School District 125  
12150 South Hamlin Ave.  
Alsip, IL 60803

**Workorder: 1711381**

TEL: (773) 827-8221

FAX:

RE: Meadow Lane Elementary 11800 Meadow Lane Dr Merrionette Park IL  
60803 Drinking Water Lead Analysis

Dear Carlos Luna:

Suburban Laboratories, Inc. received 14 sample(s) on 11/6/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez  
Project Manager  
708-544-3260 ext 214  
pat@suburbanlabs.com



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

Client ID: Atwood Heights School District 125

Project Name: Meadow Lane Elementary 11800 Meadow Lane Dr Merri

Report Date: November 15, 2017

Workorder: 1711381

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711381-001A	Teachers Lounge	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-002A	Teachers Lounge	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-003A	Westside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-004A	Westside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-005A	Westside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-006A	Westside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-007A	South Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-008A	South Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-009A	Eastside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-010A	Eastside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-011A	Eastside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-012A	Eastside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-013A	Eastside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017
1711381-014A	Eastside Hallway	ND	2.00	µg/L	11/03/17 18:30	11/4/2017	11/9/2017

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

November 15, 2017

Carlos Luna  
Atwood Heights School District 125  
12150 South Hamlin Ave.  
Alsip, IL 60803

Workorder: 1711373

TEL: (773) 827-8221

FAX:

RE: Lawn Manor School 4300 W 108th Place Oak Lawn IL 60453 Drinking  
Water Lead Analysis

Dear Carlos Luna:

Suburban Laboratories, Inc. received 22 sample(s) on 11/6/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez  
Project Manager  
708-544-3260 ext 214  
pat@suburbanlabs.com



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Atwood Heights School District 125

**Project Name:** Lawn Manor School 4300 W 108th Place Oak Lawn IL 6

**Report Date:** November 15, 2017

**Workorder:** 1711373

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711373-001A	Fountain Outside RM 24	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-002A	Fountain Outside RM 24	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-003A	Kitchen	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-004A	Kitchen	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-005A	Outside Gym Door	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-006A	Outside Gym Door	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-007A	Gym Office Sink	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-008A	Gym Office Sink	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-009A	North Hallway 5	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-010A	North Hallway 5	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-011A	North Hallway 6	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-012A	North Hallway 6	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-013A	North Hallway 7	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-014A	North Hallway 7	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-015A	Room 18	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-016A	Room 18	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-017A	Room 17	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-018A	Room 17	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-019A	Room 7	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-020A	Room 7	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-021A	Classroom 8	3.74	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017
1711373-022A	Classroom 8	ND	2.00	µg/L	11/03/17 18:00	11/4/2017	11/9/2017